

Espesores recomendados de aislamiento

Temperatura De Tubería	°C	-73	-40	-29	-18	-7	4
	°F	-100	-40	-20	0	20	40
Diámetro Nominal		Espesor Recomendado en pulgadas					
1/2"	3	2 1/2	2	2	1 1/2	1	
3/4"	3	2 1/2	2	2	1 1/2	1	
1"	3 1/2	2 1/2	2	2	1 1/2	1	
1 1/4"	3 1/2	2 1/2	2 1/2	2	1 1/2	1 1/2	
1 1/2"	3 1/2	2 1/2	2 1/2	2	2	1 1/2	
2"	4	3	2 1/2	2	2	1 1/2	
2 1/2"	4	3	2 1/2	2	2	1 1/2	
3"	4 1/2	3 1/2	2 1/2	2 1/2	2	1 1/2	
4"	4 1/2	3 1/2	3	2 1/2	2	1 1/2	
5"	4 1/2	3 1/2	3	2 1/2	2	1 1/2	
6"	4 1/2	3 1/2	3	2 1/2	2 1/2	1 1/2	
8"	5 1/2	4	3 1/2	3	2 1/2	1 1/2	
10"	5 1/2	4	3 1/2	3	2 1/2	2	
12"	6	4	3 1/2	3	2 1/2	2	

Condiciones ambientales

Humedad Relativa de 90%

Temperatura Ambiente, 90°F

Velocidad del Aire 0 millas por hora

Temperatura Superficial Mínima para prevenir condensación 87°F